

To

The Assistant Engineer(QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

RNo. 2278

09 JAN 2018

**Part I**

Dispatch No D-36/EEC-3/DUSIB/17-18

Date:- 6/1/18

Sub: Testing of RMC cubes of mix M-20 for 7/28 days Compressive Strength.

Name of work: EIUS

SH: Providing and laying CC and SW drain in deteriorated lanes in JIC Karpuri Thakur, Srinivasपुरi.

Project ID - 8921

Agency :- M/S P.M Construction

A. L. No. 26/EEC-6/DUSIB/AE-1/DUSIB/2017-18/D-552

Dated: 13-07-2017

2. Details from where sample is collected

From site

3. Name of Circle/Division:

II

4. Name of Junior Engineer:

5. Name of Assistant Engineer:

Sh. R.S Rana

6. Name of Executive Engineer:

Sh. O.P. Pruthi

7. Name of Contractor/Agency:

8. Name of Officer collecting sample:

Sh. R.S Rana

9. Date of collection:

M/S P.M Construction

10. Date of testing:

9-1-18

11. Required strength:

As per CPWD Specification

12. No. of specimen sent for testing:

-3 nos.

13. Size of specimen:

15 X 15 X 15 cm

14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-----has/have been taken in my presence which represent---quantity of works/supply made at site/store.

Signature of AE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

**Part II**

**TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-18/D- 2545

Date: 10/1/18

Test No. 2278

Date: 9-1-18

Date of Receipt: 09/1/18

Date of testing: 09/1/18

Concrete Mix:

M-20

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8332 gm	225	53.07	235.56	232.59	Accordingly
2.	8296 "	225	50.57	224.44		
3.	8546 "	225	53.57	237.78		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)  
Delhi Urban Street and Sewerage Board  
Govt. of NCT of Delhi  
ITO, New Delhi-110002

Copy to:-

1. EEC-6
2. dc