

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

2703

RNO - 2822

28 FEB 2018

Part I

Dispatch No D-102/AE-V/C-11/DUSIB/2018 Date: 28/2/18
Sub: Testing of CC cubes of mix M-15 for 28 days Compressive Strength.

A. L. No. E/WC/450/AT-40/COM/FEC-11/DUSIB/2017-18/D-585 Date: 6/12/2017

1. Name of work:- E.T.V.S
- SH: Improvement of drainage system and providing A.M.P in lanes of J5-chuster H-block, Jahangir Puri, P.D. No - 9070
2. Details from where sample is collected Promasti
3. Name of Circle/Division Circle-4/C-11
4. Name of Junior Engineer Mahender Singh
5. Name of Assistant Engineer Sh. Ajay Saxena
6. Name of Executive Engineer M/S. Anand Const. Co.
7. Name of Contractor/Agency Mahender Singh
8. Name of Officer collecting sample 31/1/2018
9. Date of collection: 28/2/18 to 5/3/18
10. Date of testing: 16.5 Kg/cm²
11. Required strength: 3 Nos
12. No. of specimen sent for testing: 15x15x15 cm
13. Size of specimen: (M-15)
14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked (M-15) has/have been taken in my presence which represent 21 cum quantity of works/supply made at site/store.

Signature of JE
In charge of work

Anam
Signature of Contractor

P Singh 28/2/18
Signature of Officer taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2016-17/D-

3150

Date: 28/02/18

Test No. 2822

Date: 28-2-18

Date of Receipt: 28/2/18

Date of testing: 28/2/18

Concrete Mix: M-15

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq. cm mm ²	Compressive Load KN (Tonnes)	Strength Comp. strength (Kg./sq. cm) N/mm ²	Average Strength (Kg./sq. cm) N/mm ²	Remarks
1.	8602 gm	22500	436 KN	19.38	19.85 N/mm ²	EE May Correlate Accordingly
2.	8513 "	22500	450 "	20.0		
3.	8544 "	22500	454 "	20.18		

Tested in my presence

[Signature] Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

[Signature] 28/2/18
Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Board
Gov. of N.C.T., of Delhi
ITC, New Delhi-02

Copy to:-

1. EE/C-11