

To,

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITO, New Delhi

W4/4814 (17) / EEC3 / DUSIB / D-564
dtd 29.6.2017

P.I.D 9080

Part I

No. 582/AE-I/C-3

Date: 6.7.17

RNO. 749

RECEIVED 06 JUL 2017

Sub: Testing of Bricks/Bricks tiles for Dimension/Compressive Strength.

1. Name of Work:- GIA (Protection of Land)
SH:- Construction of Bungalow at D-7, Block, Sukhumburi.

2. Detail from where sample is collected Above noted work.

3. Name of Circle/Division: Circle-I, C-3

4. Name of Junior Engineer SN. Yulhbir Malik, E.1

5. Name of Assistant Engineer : SN. Dorilal

6. Name of Executive Engineer: SN. V.S FONIA

7. Name of Contractor/Agency: Fair Deal Cons. Co.

8. Name of Officer collection sample : Dorilal AE

9. Date of collection/Date of filling frog: 01/07/2017-02/07/2017

10. Date of Testing: 06/07/2017

11. Identification Mark: M.B.F.

12. Class designation: 7.5

13. No. of specimen sent for testing: 20 OS

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked, M.B.F. has/have been taken in my presence which represent 20.00 quantity of work/supply made at site/store.

Yulhbir Malik
Signature of JE
Incharge of work

[Signature]
Signature of Contractor

[Signature]
Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2007/D-

Date :

Test No. 749 Date 6.7.17

Date of Receipt 6.7.17

Date of Testing 6.7.17

S. No.	Dimensions		Maximum Strength Failure (T)	Compressive Strength failure (kg/sq.cm)	Average Compressive Strength ka/sq.cm
	Length	Width			
	Area (cms) (sq.cm)	(cms)			
1.	21.40 x 10.50 = 224.70		18.00	80.11	85.25
2.	22.00 x 10.60 = 233.20		21.00	90.05	
3.	22.00 x 10.50 = 231.00		20.00	86.58	
4.	22.00 x 10.60 = 233.20		20.00	85.76	
5.	21.60 x 10.50 = 226.80		19.00	83.77	

ACCEPTABLE

DEMENSION TEST; FOR 20 BRICKS

1. Length :
2. Width : NOT ASKED for
3. Height :

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Copy to:

1. EE/C-3
2. ...

Assistant Engineer (QC) Lab-

DUSIB, Vikas Kuteer, ITO

Delhi Urban Shelter Improvement Board

Govt. of N.C.T. of Delhi