

To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kuteer, ITO, New Delhi

R.NO: 11498
RECEIVED 28 SEP 2017

Part I

Dispatch No. D-90/AE/C-9/DUSIB/2017-18

Date: 28/09/2017 28/9/2017

Sub: Testing of CC cubes of mix ---M-15--- for 28 days Compressive Strength.

A. L. No. 06/LOA/EE/C-9/DUSIB/2017-18 /D-1016

Dated: 09/08/2017

Name of work: E.P.O.S.

Sub Head: Constⁿ of S.W. drain & Raising of lanes by pvy. C.C. pavement at JJ Batti CS
Harijan Camp near Dispensary Mandawali Fazalpur
(P.B. - 9145)

1. Details from where sample is collected -----from site-----
2. Name of Circle/Division -----3/C-9-----
3. Name of Executive Engineer -----Sh. Phool Singh-----
4. Name of Assistant Engineer -----Sh. M. G. Sharma AECU-----
5. Name of Junior Engineer -----Ved Pal Meena (J.E.)-----
6. Name of Contractor/Agency -----M/s. Pooja Builders-----
7. Name of Officer collecting sample -----Ravindra Kumar (A.E.) ----- M. G. Sharma,-----
8. Date of collection: -----21/8/2017-----
9. Date of Testing -----28/9/2017-----
10. Quantity of sample sent for testing: -----Mr. B-----
11. Required strength: -----as per CPWD specifications-----
12. No. of specimen sent for testing: -----03 Nos.-----
13. Size of specimen: -----15cm X 15cm X 15cm-----
14. Mark of specimen: -----RPB-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked-----has/have been taken in my presence which represent---20 cum---quantity
of works/supply made at site/store.

28/09/2017
Signature of A.E.
In charge of work

28/09/2017
Signature of Contractor

28/09/2017
Signature of Officer taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC/AE(Lab.)/2017-18/D-1745

Date: 29/09/17

Test No. 1498 Date: 28/09/17

Date of Receipt: 28/9/2017

Date of testing: 28/9/2017

Concrete Mix: M-15

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8300 gm	225	40.0 T	177.78	185.93 kg/cm ²	
2.	8410 "	225	42.50 T	188.89		
3.	8444 "	225	43.00 T	191.11		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

29/9/17
Assistant Engineer (QC-Lab)

DUSIB, Vikas Kutir, ITO,
Assistant Engineer (QC),
Delhi Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITO, New Delhi-02

Copy to:-

1. EE/C-9