

To,

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITO, New Delhi

RNo. 2842

05 MAR 2018

Part I

No.

D-17/AE-I/C-7/2017-18

Date: 01/03/18

Sub: Testing of Bricks/Bricks tiles for Dimension/Compressive Strength.

1. Name of work: F.I.U.S

Sub-Head P/L C.C. Pavement to drain in lanes at JTC Sethi Camp, Gandhi Vihar Colony
Opp. Sant Nihankali Sh. Sec. School, Nihankali Colony (P.D.-9287)

Acceptance Letter No. : WI/6031/ 70 /PG/EE C-7/2017-18 /D-1463 dated : 5-12-17

2. Detail from where sample is collected: Above noted work.

3. Name of Circle/Division: Circle-III/C-7.

4. Name of Junior Engineer: Sh. Sunil Madan

5. Name of Assistant Engineer: Sh. K.L. Maurya

6. Name of Executive Engineer: Sh. Rajimall Bansal

7. Name of Contractor/Agency: M/s D. & P Const. Co

8. Name of Officer collection sample : Sh. K.L. Maurya

9. Date of collection/Date of filling frog : 01/03/18

10. Date of Testing: 05/03/18

11. Identification Mark: A.I.T.

12. Class designation: 7.5

13. No. of specimen sent for testing: 05 Nos.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked Sethi Camp has/have been taken in my presence which represent 30000 quantity of work/supply made at site/store.

Staden
Signature of JE
In-charge of work

P. N. H.
Signature of Contractor

Maurya
Signature of Officer
taking sample (EE/AE)

Part IITEST REPORT

No. SE (QC)/AE (Lab)/2016/D- 3177

Date : 05/03/18

Test No. 2842 Date 5.3.18

Date of Receipt 05/3/18

Date of Testing 05/3/18

A.S.I.T

S. No.	Dimensions			Maximum Strength Failure (T)	Compressive Strength failure (kg/sq.cm)	Average Compressive Strength kg/sq.cm
	Length (cms)	Width (cms)	Area (sq.cm)			
1.	22.70	10.90	247.43	22.00 T	88.91	90.07 kg/cm ²
2.	22.60	11.00	248.60	24.50 T	98.55	
3.	22.70	11.00	249.70	21.00 T	84.10	
4.	22.50	10.80	243.00	26.00 T	107.07/10	
5.	22.50	11.00	247.50	19.50 T	78.29	

ACCEPTABLE

DEMENSION TEST: FOR 20 BRICKS

1. Length :

2. Width :

3. Height :

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to: EE/C-7

1.

2. o/c

Maurya
Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board