

To,

The Assistant Engineer (QC)  
Quality Control Lab, DUSIB  
Vikas Kutir, ITO, New Delhi

2953

RNo. 2843

Part I

No. D-18/AE-I/C-7/2017-18 Date: 01/8/18

05 MAR 2018

Sub: Testing of Bricks/~~Bricks~~ Tiles for Water Absorption/Efflorescence.

1. Name of work: ETUS  
Sub-Head :- P/L C.C. Pavement & drains in lanes at JSC Sethi Camp, 9m wide vihal colony, off Sant Vikramaji St. Sec School, Vikramaji Colony (AT D 9287)

Acceptance Letter No. : WI/6031/70/PG/EE C-7/2017-18 /D-1463 dated : 5-12-17

2. Detail from where sample is collected: Above noted work.  
3. Name of Circle/Division: Circle-III/ C-7  
4. Name of Junior Engineer: Sh. Sunil Madan  
5. Name of Assistant Engineer: Sh. K.L. Maurya  
6. Name of Executive Engineer: Sh. Rajinder Bansal  
7. Name of Contractor/Agency: M/s D.A. P. Const. Co.  
8. Name of Officer collection sample : Sh. K.L. Maurya  
9. Date of collection/Date of filling frog: 01/03/18  
10. Date of Testing: 05/03/18  
11. Identification Mark: AJIT  
12. Class designation: 7.5  
13. No. of specimen sent for testing: 10

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked Sethi Camp has/have been taken in my presence which represent 300.00 quantity of work/supply made at site/store.

Stedem  
Signature of JE  
In-charge of work

P. N. Mittal  
Signature of Contractor

Maurya  
Signature of Officer  
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2018/D-

Date :

Test No. 2843 Date 5.3.18

Date of Receipt 05/03/18

Date of Testing 05/03/18

(A) WATER ABSORPTION

AJIT

Day of Testing upto 8.3.18

S. No.	Dry Wt. (gms)	Wet Wt.(gms)	Water Absorbed (gms)	%age water Absorbed	Average absorption water
1.	3264	3664	400	12.25	14.67% <b>ACCEPTABLE</b>
2.	3164	3621	457	14.44	
3.	3133	3697	564	18.00	
4.	3134	3602	468	14.93	
5.	3173	3609	436	13.74	

(B) EFFLORESCENCE

Dt. Of testing upto: 23/03/18

**ACCEPTABLE**

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to: EE/C-7

1. o/c  
2. o/c

Maurya  
Assistant Engineer (QC) Lab.  
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)  
Delhi Urban Shelter Improvement Board  
Govt. of N.C.T., of Delhi  
ITO, New Delhi-02