

To

The Assistant Engineer (QC)  
Quality Control Lab., DUSIB  
Vikas Kuteer, ITO, New Delhi

3065

R.No: 0056 FD: 9302  
12 APR 2018

## Part I

Dispatch No. AE1/C-9/DUSIB/2017.18/D-361 Date: 12/4/18

Sub: Testing of CC cubes of mix ~~M-20~~ for 28 days Compressive Strength.

A. L. No. 49/LOA/EE/C-9/DUSIB/2017.18/D-1350

Dated: 30-12-2017.

Name of work: MLA LAD FUND.

Sub Head: PL CC Pavement & C/P S.W. Drains in lanes b/w block-9A, 10A (2. Nov)  
Transit Camp, Trilokpur area.

1. Details from where sample is collected -----from site-----
2. Name of Circle/Division -----3/C-9-----
3. Name of Executive Engineer -----Sh. Ram Das-----
4. Name of Assistant Engineer -----Sh. Veer Bahadur Singh-----
5. Name of Junior Engineer -----Sh. S.N. Khurana-----
6. Name of Contractor/Agency -----M/s Mohender Singh-----
7. Name of Officer collecting sample -----Sh. Veer Bahadur-----
8. Date of collection: -----15.3.18-----
9. Date of Testing -----12.4.18-----
10. Quantity of sample sent for testing: -----3 Nos.-----
11. Required strength: -----as per CPWD specifications-----
12. No. of specimen sent for testing: -----03 Nos.-----
13. Size of specimen: -----15cm X 15cm X 15cm-----
14. Mark of specimen: -----RPB A-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/  
samples marked A has/have been taken in my presence which represent 120 cum quantity  
of works/supply made at site/store.

Signature of AE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)

## Part II

## TEST REPORT

No. SE(QC)/AE(Lab.)/2017.18/D- 066

Date: 16/04/18

Test No. 0056 Date: 12/04/18

Date of Receipt: 12/4/18

Date of testing: 12/4/18

Concrete Mix: M-20

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq. cm.	Compressive Strength		Average Strength (Kg./sq. cm.)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq. cm.)		
1.	8534 gm	2250	528	23.47	23.79 N/mm <sup>2</sup>	EE may Certificate Accordingly
2.	8562 "	2250	537	23.87		
3.	8599 "	2250	541	24.04		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and  
handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)

DUSIB, Vikas Kutir, ITO -  
Assistant Engineer (QC)

Delhi Urban Sector Development Board  
3001, ITO, New Delhi

Copy to:-

EE/C-9