To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kuteer, ITO, New Delhi

RNo. 2966

15 MAR 2018

Part I

Dispatch No AE-I / C-9/DUSIB/2017-18 / D- 83 Date: 15/3/18

Sub: Testing of CC cubes of mix ----M-~~25~~ 20 ------ for 28 days Compressive Strength.

A. L. No. 50 /LOA/EE/C-9/DUSIB/2017-18 /D- 1351 *Dated:* 30/12/17.

Name of work: MLA LAD Fund.

Sub Head: P/L CC Pavement & Construction of S.W drain in lanes of market b/w block 6,7 & 10-11 block, Trilokpuri (AC-55).

1. Details from where sample is collected ------ *from site* ----------
2. Name of Circle/Division ------3/C-9----------
3. Name of Executive Engineer ------ *Sh. Ram Das* ----------
4. Name of Assistant Engineer -------Sh. Veer Bahadur Singh----------
5. Name of Junior Engineer -------Sh. S. N. Khurana----------
6. Name of Contractor/Agency M/s D.K Const Co
7. Name of Officer collecting sample -------- Sh. Veer Bahadur Singh ----------
8. Date of collection: 15-2-18
9. Date of Testing 15-3-18
10. Quantity of sample sent for testing: 3 Nos CUBES
11. Required strength: ---*as per CPWD specifications*----------
12. No. of specimen sent for testing: ------*03 Nos.*----------
13. Size of specimen: -------*15cm X 15cm X 15cm*----------
14. Mark of specimen: AEI

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked---AEI---has/have been taken in my presence which represent *20 cum*--quantity of works/supply made at site/store.

Signature of AE In charge of work | Signature of Contractor | Signature of Officer taking sample (EE/AE)

Part II **TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-18/D- 3315 Date: 15/03/18

Test No. 2966 Date: 15.3.18

Date of Receipt: 15/3/18

Date of testing: 15/3/18

Concrete Mix: M.20 Days test: 28 days

S. No	Wt. of specimen in gms	Area in ~~sq.cm.~~ mm²	Compressive Strength: Load ~~(Tonnes)~~ KN	Comp. strength ~~(Kg./sq.cm)~~ N/mm²	Average Strength ~~(Kg./sq.cm)~~ N/mm²	Remarks
1.	8382gm	22500	532	23.64	24.24 N/mm²	
2.	8444 "	22500	544	24.18		
3.	8470 "	22500	560	24.88		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/~~samples~~ has/~~have~~ been collected and handed over by the field staff of the concerned division.

15/3/18

Assistant Engineer (QC-~~Lab~~)
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EE/C-9