

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R No. 2139
RECEIVED 22 DEC 2017

Part I

Dispatch No. D-51/AETTT/EEC-10/DUSIB/2017-18 Date: 22.12.17
Sub: Testing of CC cubes of mix RMC M-25 for 7/28 days Compressive Strength.

A. L. No. WB/4321/A1-63/EEC-10/DUSIB/17-18/D-1920 Date: 8.11.17

1. Name of work:- MLA IAD fund.
SH: Providing & laying CC Pavement & Drainage in Gali No. 4, 6, 7 Block-4 and Gali No. 7, Krishna Nagar, Dev Nagar in Ac-23, Karol Bagh. (P.ID-000009343)
2. Details from where sample is collected Site of work.
3. Name of Circle/Division 41C-10
4. Name of Junior Engineer Sh. Brahmopal Singh.
5. Name of Assistant Engineer Sh. Shyam Singh.
6. Name of Executive Engineer M/s. Mahesh & Co.
7. Name of Contractor/Agency Sh. Brahmopal Singh.
8. Name of Officer collecting sample 22.11.17
9. Date of collection: 21.12.17/22.12.17
10. Date of testing: m-25
11. Required strength: 3 Nos
12. No. of specimen sent for testing: 15 x 15 x 15 cm
13. Size of specimen: 1, 3, 5.
14. Mark of specimen:

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/s marked See above has/have been taken in my presence which represent See above quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18/D- 2498

Date: 29/12/17

Test No. 2139 Date: 22-12-17

Date of Receipt: 22/12/17

Date of testing: 22/12/17

Concrete Mix: m-25

Days test: 30 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8292gm	225	61.50T	273.33	277.04	ACCEPTABLE
2.	8446	225	62.50T	277.78		
3.	8494	225	63.25T	280.22		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/s has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Copy to:-
EE/c-10
o/c

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi