

To,
The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kurtir, ITO, New Delhi

2214

RNO- 2404

19 JAN 2018

Part-I

Dispatch No. D- 74A.E-III/EEC-10/DUSIB/2017-18

Date: 19.01.2018

Sub: Testing of CC Cube of Mix RMC M-25 for 7/28 days Compressive Strength.

A.L No. : WB/4321/AL-68/EEC-10/DUSIB/2017-18/D-1950 Date: 14.11.2017

1 Name of Work : MLA LAD FUND
Sub Head : Providing & Laying CC Pavement and Drainage in Link Road, Jhandewalan in AC-23 Karol Bagh. (Project ID 000009344)

- 2 Details from where sample is collected: Site as Above
- 3 Name of Circle /Division: 4/C-10
- 4 Name Of Junior Engineer:
- 5 Name Of Assistant Engineer: Sh. Braham Pal Singh
- 6 Name Of Executive Engineer: Sh. Shyam Singh
- 7 Name Of Contractor /Agency: M/S Manni Mahesh & Co.
- 8 Name Of Officer Collecting Sample: Sh. Braham Pal Singh
- 9 Date of Collection: 22-12-17
- 10 Date of Testing: 19-01-18
- 11 Required Strength: M-25
- 12 No. of Specimen Sent for testing: 3 Nos
- 13 Size of Specimen : 150x150x150mm
- 14 Mark of Specimen: 1, 3, 5

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked **sealed in bag** Has/have been taken in my presence which represent ~~Sample~~ Quantity of works/supply made at site/ store.

Signature of JE
Incharge of Work

Signature of Contract

Signature of Officer
Taking sample (AE)

Part-II

TEST REPORT

No. SE (QC)/AE (Lab)/ 2017-18/D-

2683

Date: 23/1/18

Test No.: 2404

Date: 19.1.18

Date of Receipt: 19/1/18

Date of Testing: 19/1/18

Concrete mix:

S. No.	Wt. Of specimen in grams	Area in sq.cm mm ²	Compressive strength		Average Strength (kg./sq.cm) N/mm ²	Remarks
			Load KN (Tonnes)	Comp.stren gth (kg./sq.cm) N/mm ²		
1	8360 gm	2250	655 KN	29.11	28 days EE May Correlate Accordingly	
2	8398 gm	2250	640 KN	28.44		
3	8452 gm	2250	664 KN	29.51		

Tested in my presence

Only testing has been conducted in the Laboratory. The sample has been collected and handed over by field staff of the concerne division.

Signature
19/1/18