

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITO, New Delhi
Part I
AL No. 53/-----/D-639

2525

Rm 2479

24 JAN 2018

Date: 24/10/17

Sub: Testing of Bricks / Bricks Tiles for Water Absorption / Efflorescence

Name of work: Pay and Use JSC

Sub Head: Renovation/ upgradation 36ater conventional JSC at JJC Garib Basi RamaRoad
(PMS no.9347).

2. Details from where sample is collected: From Site
3. Name of Circle / Division: Circle 2/C-4
4. Name of Junior Engineer: Sh. Harish Chauhan
5. Name of Assistant Engineer: Sh. Subhash Gaur
6. Name of Executive Engineer: Sh. Anil Aggarwal
7. Name of Contractor / Agency: M/s Rajneesh Oberoi
8. Name of Officer Collecting Sample: Sh. Subhash Gaur
9. Date of collection / Date of filling frog: 19.1.18 / 20.1.18
10. Date of testing: 20.1.18
11. Identification Mark: 75 ANAND
12. Class Designation: 10
13. No. of specimen sent for testing: 10

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked ANAND has / have been taken in my presence which represent quantity of work / supply made at site / store.

Signature of J.E.

Signature of Contractor

Signature of Officer

Taking sample (J.E. / AE)

Part II

No. SE(QC/AE(Lab)/2016-17/D-

Test No. 2499 Date 24.1.18

Date of Receipt 24.1.18

Date 19.10.2018

(A) WATER ABSORPTION

ANAND

Date of testing up to 30.1.18

S. No.	Dry Weight (Grams)	Wet Weight (Grams)	Water Absorbed (Grams)	% age Water Absorbed	Average Water Absorption
1.	3324	3727	403	12.12	11.86%
2.	2920	3292	372	12.74	
3.	3139	3489	350	11.15	
4.	3302	3693	391	11.84	
5.	3303	3681	378	11.44	

(B) EFFLORESCENCE

Date of testing upto 12.2.18

Efflorescence found: Nil / Slight / Moderate / Heavy

Only testing has been conducted in this laboratory, the sample has been collected, cured and handed over by the field staff of the division.

Assistant Engineer(QC) Lab.

DUSIB.

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to:

1. EEIC-4
2. dc