

To
The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R-ND: 1835
RECEIVED 23 NOV 2017

Part I

Dispatch No D-6301/AE-II/C-12/DUSIB/17 Date: 23-11-17

Sub: Testing of CC cubes of mix RMC M-25 for 28 days Compressive Strength.

AL No. 28/WK/7205(181)/EEC-12/DUSIB/2017-18 /D- 596 dated 26.07.2017

NOW: EIUS.SH:C/O approach Road and providing drainage system in the road between two newly constructed prefab JSC in Block E and BVK to Panch mandir JSC (New) in Block F at JJ Cluster Shahbad Daulatpur. (Project ID 000009356).

1. Details from where sample is collected New BVK Block F
2. Name of Circle/Division Circle-4/C-12
3. Name of Junior Engineer -----
4. Name of Assistant Engineer A.K. Gupta
5. Name of Executive Engineer Sh. Kamal Singh
6. Name of Contractor/Agency M/S V.R. Constructions
7. Name of Officer collecting sample A.K. Gupta
8. Date of collection: 25-10-17
9. Date of testing: 23-11-17
10. Required strength: M 25
11. No. of specimen sent for testing: 03
12. Size of specimen: 15X15X15 cm
13. Mark of specimen: (1)

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-----(+)-----has/have been taken in my presence which represent 50 m² quantity of works/supply made at site/store.

V. K. Singh
Signature of Contractor

A. K. Gupta
Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2016-17/D- 2147

Date: 23/11/17

Test No. 1835 Date: 23/11/17

Date of Receipt: 23/11/2017

Date of testing: 23/11/2017

Concrete Mix: M 25

Days test: 29 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8414 gm	225	61.50 T	273.33	277.78 kg/cm ²	EE May Correlate Accordingly
2.	8502 gm	225	64.00 T	284.44		
3.	8456 "	225	62.00 T	275.56		

Tested in my presence A. K. Gupta

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

A. K. Gupta
Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Copy to:-

1. EE/C-12

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
New Delhi