

To

The Assistant Engineer(QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

2348

RNO. 2542

30 JAN 2018

Part IDispatch No. D-82(2)/AE-IT/12/DUSIB/17-18 Date: 30-1-18

Sub: Testing of CC cubes of mix M-30 for 28 days Compressive Strength.

AL No. 34/WK/7205(182)/EEC-12/DUSIB/2017-18/D-763

dated 26.09.2017

NOW: Improvement of SC/ST Basties of NCT of Delhi

SH: Repair/Restoration by providing and laying RMC pavement on 15m and 9m road including covering and repairing of drain etc. At Shahbad Daulatpur (Shahbad Dairy) (Project ID 000009391)

1. Details from where sample is collected Shahbad Dairy
2. Name of Circle/Division Circle-4/C-12
3. Name of Junior Engineer \_\_\_\_\_
4. Name of Assistant Engineer A.K. Gupta
5. Name of Executive Engineer Sh. Kamal Singh
6. Name of Contractor/Agency M/S Pushpa Builders
7. Name of Officer collecting sample A.K. Gupta
8. Date of collection: 2-1-18
9. Date of testing: 30-1-18
10. Required strength: M-30
11. No. of specimen sent for testing: 03
12. Size of specimen: 15X15X15 cm
13. Mark of specimen: (2)

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked (2) has/have been taken in my presence which represent 50 m<sup>2</sup> quantity of works/supply made at site/store.

Signature of Contractor

Signature of Officer  
taking sample (EE/AE)Part IITEST REPORTNo. SE(QC)/AE(Lab.)/2016-17/D- 2613Date: 31/1/18Test No. 2542 Date: 30-1-18Date of Receipt: 30/1/18Date of testing: 30/1/18Concrete Mix: M-30Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq. cm. mm <sup>2</sup>	Compressive Strength		Average Strength (Kg./sq. cm) N/mm <sup>2</sup>	Remarks
			Load (Tonnes) KN	Comp. strength (Kg./sq. cm) N/mm <sup>2</sup>		
1.	8492 gm	22500	876	38.93	38.12	EE May Correlate Accordingly
2.	8432 gm	22500	862	38.31		
3.	8560 gm	22500	8358	37.11		

Tested in my presence A.K. Gupta

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Copy to:-

1. EE/C-122. etc

Assistant Engineer (QC-Lab) 30/1/18  
DUSIB, Vikas Kutir ITO  
Assistant Engineer (QC)  
Delhi Urban Shelter Improvement Board  
Govt. of NCT of Delhi  
ITO, Vikas Kutir