RECEIVING
ID:- 00009514
08 JAN 2018
RNo. 2261

To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

Part I

Dispatch No AE-VIII/C-11/DUSIB/2018/D-184 Date: 8/1/18

Sub: Testing of Bricks/~~Brick tiles~~ for Compressive Strength/Dimension.

A. L. No. F/WC/4450/AL-39/EE/C-11/DUSIB/2017-18/D-512 Date: 4.12.2017

1. Name of work: C/O JSC :- Const. of 100 Seater Prefab JSC in JJC
   SH: Sanjay Camp Gali no:- 9 Samoi pur Badli
2. Details from where sample is collected: From site
3. Name of Circle/Division: C-4 C-11
4. Name of Junior Engineer: N.K. MENGHANI
5. Name of Assistant Engineer: M.K. GARG
6. Name of Executive Engineer: SH. Ajay
7. Name of Contractor/Agency: SH. M.K. GOYAL
8. Name of Officer collecting sample: M.K. GARG
9. Date of collection/Date of filling frog: 03/1/18 / 04/1/18
10. Date of testing: 08/1/18
11. Identification Mark: KBF
12. Class designation: 75 kg/cm2
13. No. of specimen sent for testing: 05 Nos M.K.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked M.K. has/have been taken in my presence which represent 6000 quantity of works/supply made at site/store.

Signature of JE
Incharge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab.)/2017-18/D- 2531 Date: 10/1/18

Test No. 2261 Date: 8.1.18

Date of Receipt: 08/1/18

Date of Testing: 08/1/18

(A) COMPRESSIVE STRENGTH KBF

S. No	Dimensions Length (cms)	Width (cms)	Area (sq.cm)	Maximum Strength. Failure (T)	Compressive Strength Failure (kg/sq.cm)	Av. Comp. Strength. Kg/sq.cm
1.	21.50	10.50	225.75	26.00 T	115.17/100	ACCEPTABLE
2.	21.60	11.00	237.60	22.00 T	92.59	
3.	21.50	10.50	225.75	20.00 T	88.59	92.83
4.	21.60	10.60	228.96	23.0 T	100.45/100	kg/cm²
5.	21.60	10.60	228.96	19.0 T	82.98	

Tested in my presence

Required strength 75 kg/cm²

(B) DIMENSION TEST FOR 20 BRICKS

1. Length :
2. ~~Width~~ : not arranged
3. Height :

Only testing has been conducted in this laboratory. The sample/~~samples~~ has/~~have~~ been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab) 08/1/18
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITO, New Delhi-02

Copy to:-
1. EE/C-11
2.