

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITO, New Delhi

RHD - 2184

RECEIVED 29 DEC 2017

Part I

No. J.98.1.A.E.-10/C-2/ DUSIB

Date... 29.12.17

Sub: Testing of CC cubes of mixM-25..... for 7/28 days Compressive Strength.

AL. No:-09/WF/4766(25)/AE-III/EEC-2/DUSIB/2017-18/D-494 Dt.12.10.2017

1. Name of work: Imp. of SC/ST Basties.

Sub Head:- Repair/ Raising the Lanes at Balmiki Basti at Villlage Rasoolpur (AC-8) Mundka Constituency.

- 2. Details from where sample is collected: From Site.....
- 3. Name of Circle / Division: ...C-2.....
- 4. Name of Junior Engineer: Sh. Ravinder Kumar
- 5. Name of Assistant Engineer: Sh. P.S. Johar
- 6. Name of Executive Engineer: Sh. S.C. Sharma
- 7. Name of Contractor / Agency: M/S Manjit Const. Co..
- 8. Name of Officer Collecting Sample: Sh.P.S. Johar
- 9. Date of collection :
- 10. Date of testing: 1.12.17
- 11. Required Strength: 29.12.17
- 12. No. of specimen sent for testing: 1 No
- 13. Size of specimen: 150x150x150
- 14. Mark of specimen: 11m

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked Sign has / have been taken in my presence which represent quantity of work / supply made at site / store.

Signature of J.E. Rohme

Signature of Contractor No

Signature of Officer Taking sample (EE / AE)

Date... 29/12/17

Date of Receipt.....

Part II

No. SE(QC)/AE(Lab)/2017/D- 2442

Test No... 184 Date... 29.12.17

Date of Testing... 29/12/17

Concrete Mix M-25

Day Test... 28 days

S. No	Wt. of specimen (In gms.)	Area (In Sq. cm.)	Compressive Strength		Average Strength (In Kg/sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (In Kg/sq.cm)		
1.	8522 gm	225	62.07	277.78	283.70	EE May Correlate Accordingly
2.	8566	225	63.07	280.00		
3.	8600	225	66.07	293.33		

Tested in my presence

Only testing has been conducted in this laboratory, the sample has been collected, cured and handed over by the field staff of the concerned division.

COPY TO:-
1 EEC-2
2 O/C

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kuteer, ITO.
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of A.C.T. of Delhi
ITC, New Delhi-62

Signature 29/12/17