

To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kuteer, ITO, New Delhi

R.No. 3003
20 MAR 2018

2928

Part I

Dispatch No. EE/C-9/DUSIB/D-256 Date: 19/3/2018
Sub: Testing of CC cubes of mix M-15 for 28 days Compressive Strength.

A.L. No. 56/LOA/EE/C-9/DUSIB/2017-18 /D-37Dated: 11/1/2018Name of work: ERUS

Sub Head: Raising of lanes by pdg, C.C. Pavement & Imp. of S.W. drain at J.B. Bath (3)
Indira Camp Near flood Dept. office Kishan Kunj Extension
(P.F.D-9561)

1. Details from where sample is collected from site
2. Name of Circle/Division 3/C-9
3. Name of Executive Engineer Sh. Ram Dass
4. Name of Assistant Engineer MG Sharma (A.E.)
5. Name of Junior Engineer Ved Pal Meena (J.E.)
6. Name of Contractor/Agency M/s Agnathi Enterprises
7. Name of Officer collecting sample MG Sharma (A.E.)
8. Date of collection: 20/2/2018
9. Date of Testing 20/3/2018
10. Quantity of sample sent for testing: 3 Nos
11. Required strength: as per CPWD specifications
12. No. of specimen sent for testing: 03 Nos.
13. Size of specimen: 15cm X 15cm X 15cm
14. Mark of specimen: RPB

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked-----has/have been taken in my presence which represent 20 cum quantity
of works/supply made at site/store.

[Signature]
Signature of P.E.
In charge of work

[Signature]
Signature of Contractor

[Signature]
Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2011-18/D- 3362Date: 20/03/18Test No. 3003 Date: 20/3/18Date of Receipt: 20/3/18Date of testing: 20/3/18Concrete Mix: M-15Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq. cm mm ²	Compressive Strength		Average Strength (Kg./sq. cm) N/mm ²	Remarks
			Load (Tonnes) KN	Comp. strength (Kg./sq. cm) N/mm ²		
1.	8363 gm	22500	397	17.64	18.49 N/mm ²	EE May Correlate Accordingly
2.	8392 "	22500	421	18.71		
3.	8432 "	22500	430	19.11		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

[Signature]
Assistant Engineer (QC-Lab)

DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Devi Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITO, New Delhi-62

Copy to:-

1. EE/C