

ID- 9610

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer, ITO, New Delhi

RNo. 2148

RECEIVED 22 DEC 2017

Part I

No. 185/AE-III/C-2/DUSIB

Date... 22.12.17..

Sub: Testing of CC cubes of mixM-25..... for 7/28 days Compressive Strength.

AL. No:-09/WF/4766/25/AE-III/EEC-2/DUSIB/2017-18/D-494 Dt.12.10.2017

1. Name of work: Imp. of SC/ST Basties.

Sub Head:- Repair/Raising of Lanes at Harijan Basti and Badi Basti (SC/ST Community) at village Jyonti (AC-8) Mundka.

2. Details from where sample is collected: From Site.....
3. Name of Circle / Division: ...C-2.....
4. Name of Junior Engineer: Sh. Ravinder Kumar
5. Name of Assistant Engineer: Sh. P.S. Johar
6. Name of Executive Engineer: Sh. S.C. Sharma
7. Name of Contractor / Agency: M/S L.K. Builders & Supplier.
8. Name of Officer Collecting Sample: Sh.P.S. Johar
9. Date of collection : 24.11.17.....
10. Date of testing: 22.12.17.....
11. Required Strength:
12. No. of specimen sent for testing: 1 No.....
13. Size of specimen: 1.5 x 1.5 x 1.5.....
14. Mark of specimen: Sign.....

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked Sign.....has / have been taken in my presence which represent quantity of work / supply made at site / store.

Signature of J.E.

Signature of Contractor

Signature of Officer
Taking sample (EE / AE)

Part II

No. SE(QC)/AE(Lab)/2017/D- 4507

Date... 29/12/17..

Test No. 148.....Date.....

Date of Receipt... 22/12/17..

Date of Testing... 22/12/17..

Concrete MixM-25

Day Test... 28 days.....

S. No	Wt. of specimen (In gms.)	Area (In Sq. cm.)	Compressive Strength		Average Strength (In Kg/sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (In Kg/sq.cm)		
1.	8492gm	225	64.07	284.44	22/11 kg/cm ²	EE M... Corre... Accordingly
2.	8448gm	225	66.07	293.33		
3.	8508gm	225	66.507	295.56		

Signed in my presence

Only testing has been conducted in this laboratory, the sample has been collected, cured and handed over by the field staff of the concerned division.

EE/C-2
o/c

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kuteer, ITO.

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T., of Delhi
ITO, New Delhi-52