

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R.NO: 2483

24 JAN 2018

Part I

Dispatch No. 213/AE-DI/C-2/DUSIB

Date: 24.1.18

Sub: Testing of CC cubes of mix M25 for 7/28 days Compressive Strength.

A. L. No. _____

1. Name of work:-

SH:

2. Details from where sample is collected

3. Name of Circle/Division

4. Name of Junior Engineer

5. Name of Assistant Engineer

6. Name of Executive Engineer

7. Name of Contractor/Agency

8. Name of Officer collecting sample

9. Date of collection:

10. Date of testing:

11. Required strength:

12. No. of specimen sent for testing:

13. Size of specimen:

14. Mark of specimen:

Imp. of. sc/st. Baithe
Baithe (sc/st. Community) Road Village Jyoti AC-8 Mundla
From Site
C-2
Mr. Ravinder Kumar
P. S. Jahan
Satish Sharma
M/s L.K. Builders & Suppliers
P. S. Jahan
27.12.17
24.1.18
M25
1 No.
15x15x15cm
Gm

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked 15x15x15cm has/have been taken in my presence which represent _____ quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18/D- 2757

Date: 31/1/18

Test No. 2483 Date: 24.1.18

Date of Receipt: 24/1/18

Date of testing: 24/1/18

Concrete Mix: M25

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq. cm mm ²	Compressive Strength		Average Strength (Kg./sq. cm) N/mm ²	Remarks
			Load K.N (Tonnes)	Comp. strength (Kg./sq. cm) N/mm ²		
1	8710 gm	2250	690	30.67	30.76 N/mm ²	EE May Correlate Accordingly
2	8618 gm	2250	704	31.29		
3	8626 gm	2250	682	30.31		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to:-

- EE/C-2
- etc