

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer. ITO, New Delhi

2980

R.No: 3059

26 MAR 2018

Part I

No. 235./A.E.-III./C-2/DUSIB

Date: 26/03/2018

Sub: Testing of CC cubes of mix M:-25 for 7/28 days Compressive Strength.

AL. No:- WF/4766(19)/AE-III/C-2/2016-17D-527 Dated:-30/10/2017

1. Name of work: Imp. of SC/ST Basties.

Sub Head:- Providing & Laying cement concrete pavement & construction of drains by raising the level in main lanes of SC/ST Basti at C-5 Khatik Mohalla Swarn Park Mundka.

2. Details from where sample is collected: From Site.....
3. Name of Circle / Division: ...C-2.....
4. Name of Junior Engineer: Sh. Ravinder Kumar
5. Name of Assistant Engineer: Sh. P.S. Johar
6. Name of Executive Engineer: Sh. S.C. Sharma
7. Name of Contractor / Agency: M/S L.K. Builders & Supplier.
8. Name of Officer Collecting Sample: Sh.P.S. Johar
9. Date of collection : 25/02/2018
10. Date of testing: 25/03/2018, 26/03/2018
11. Required Strength:
12. No. of specimen sent for testing:
13. Size of specimen: 15X15X15 cm.
14. Mark of specimen: Sign:.....

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked has / have been taken in my presence which represent quantity of work / supply made at site / store.

Signature of J.E.

Signature of Contractor

Signature of Officer
Taking sample (EE / AE)

Part II

No. SE(QC)/AE(Lab)/2006/D- 3422

Test No. 2059 Date: 26/03/18

Date of Testing: 26/3/18

Date: 26/03/18
Date of Receipt: 26/3/18

Concrete Mix M:-25

Day Test: 29 day

S. No	Wt. of specimen (In gms.)	Area (In Sq. cm.) mm ²	Compressive Strength		Average Strength (In Kg/sq. cm)	Remarks
			Load (Tonnes) KN	Comp. strength (In Kg/sq. cm) N/mm ²		
1.	8404gms	2250	700	31.11		
2.	8449 "	2250	682	30.31	30.67	
3.	84720	2250	688	30.58		

Tested in my presence

Only testing has been conducted in this laboratory, the sample has been collected, cured and handed over by the field staff of the concerned division.

COPY TO:-

1. EE/C-2

2. o/c

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kuteer, ITO.