

To

The Assistant Engineer (QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

4/38

RNO-761

25 OCT 2018

Part I

Dispatch No. D-448/AE/IT/C-1/DUSIB Date: 25/10/18

Sub: Testing of cc cubes of mix M-15 for 7/28 days compressive strength.

A. L. No. WA/4222/PL No 04/EEC-1/2018-19/D-166 dt 26/5/2018

1. Name of work:- E.I.U.S.
2. S.H.: P/L CC Pavement c/o SW drain in the remaining lanes of SSC W2 E-Block along Rewari Railway line Mayapuri (3838)
3. Details from where sample is collected Mayapuri
3. Name of Circle/Division C-1
4. Name of Junior Engineer Sh. Sachin Kumar
5. Name of Assistant Engineer Sh. M.C. Dhingra
6. Name of Executive Engineer Sh. I.K. Shrivastav
7. Name of Contractor/Agency M/s Aarav Construction Company
8. Name of Officer collecting sample Sh. M.C. Dhingra
9. Date of collection: 26/9/18
10. Date of testing 25/10/18
11. Required strength M-15
12. No. of specimen sent for testing 1 Nos. (3 cubes)
13. Size of specimen 150 x 150 x 150 mm
14. Mark of specimen

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-----has/have been taken in my presence which represent-----quantity of works/supply made at site/store.

Hime
Signature of JE/AE
In charge of work

Dolly
Signature of Contractor

Hime
Signature of Officer
taking sample (JE/AE)

Part II**TEST REPORT**

No. SE (QC)/AE (Lab.)/2018-19/D-1130

Test No. 961 Date: 25.10.18

Date of Receipt: 25.10.18

Date of testing: 25.10.18

Concrete mix: M-15

Days test: 29 days

S.No.	Weight of specimen in gms	Area in sq mm	Compressive strength		Average strength N/mm ²	Remarks
			Load KN	Compressive strength N/mm ²		
1	8500 gm	22500	422	18.76	18.61 N/mm ²	May Correlate Accordingly
2	8529 "	22500	410	18.22		
3	8488	22500	424	18.84		

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

[Signature]
Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Tow. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to:-

1. EE/C-1
2. O/C