

To

The Assistant Engineer (QC)  
Quality Control Lab., DUSIB  
Vikas Kutir, ITO, New Delhi

4139

RNo. 962

25 OCT 2018

**Part I**Dispatch No. D-449/AE-1/C-1/DUSIB Date: 25/10/18Sub: Testing of cc cubes of mix M-15 for 7/28 days compressive strength.A. L. No. WA/4222/AL No 4/EEC-1/2018-19/D-166 dt 26/5/2018

- Name of work: E.I.V.S.
- S.H.: P/W CC Pavement C/SW drain in the remaining lanes of JTC WZ.E-Block along Rewari Railway line Mayapuri (3838)
- Details from where sample is collected Mayapuri
- Name of Circle/Division C-1
- Name of Junior Engineer Sh. Sachin Kumar
- Name of Assistant Engineer Sh. H.C. Dhingra
- Name of Executive Engineer Sh. I.K. Shrivastav
- Name of Contractor/Agency M/s Aaron Construction Company
- Name of Officer collecting sample Sh. H.C. Dhingra
- Date of collection: 26/9/18
- Date of testing 25/10/18
- Required strength M-15
- No. of specimen sent for testing 1 Nos. (3 cubes)
- Size of specimen 150 x 150 x 150 mm
- Mark of specimen

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked-----has/have been taken in my presence which represent-----quantity of works/supply made at site/store.

[Signature]  
Signature of JE/AG  
In charge of work

[Signature]  
Signature of Contractor

[Signature]  
Signature of Officer  
taking sample (JE/AE)

**Part II****TEST REPORT**

No. SE (QC)/AE (Lab.)/2018-19/D-1131

Test No. 962 Date: 25.10.18Date of Receipt: 25.10.18Date of testing: 25.10.18Concrete mix: M-15Date: 29/10/18Days test: 29 days

S.No.	Weight of specimen in gms	Area in sq mm	Compressive strength		Average strength N/mm <sup>2</sup>	Remarks
			Load KN	Compressive strength N/mm <sup>2</sup>		
1	8528 gm	2250	419	18.62	18.32 N/mm <sup>2</sup> EE May Correlate	
2	8460 "	2250	408	18.13		
3	8473 "	2250	410	18.22		

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

[Signature] 25/10/18  
Assistant Engineer (QC-Lab)  
DUSIB, Vikas Kutir, ITO  
Assistant Engineer (QC)  
Delhi Urban Shelter Improvement Board  
Govt. of N.C.T., of Delhi  
PG, New Delhi-02

Copy to:-

- EE/C-1
- o/c