RNO-2567

RECEIVED 03 MAR 2017

The Assistant Engineer (QC)
Quality Control Lab DUSIB
Vikas kutir ITO New Delhi

Part –I

Dispatch No: : .. AE-I/EEC-4/DUSIB/2016-17/D-1326 Date 09.03.2017

Sub: Testing Bricks for Water Absorption / efflorescence.

W.O.NO : - AL-81/ WD/4541/336/15/AE-II/EE-C-4/DUSIB/2016-17/D-801 Date 21/10/2016

1. Name of work : Pay and Use (JSC)

S.H : Construction of double storey 40 seater conventional JSCNo.1 at N-86 Lawrance road.

2. Details from where sample as collected — Form the site 2/P-00000 4138
3. Name of circle Division — Circle –2/ C-4
4. Name of Junior Engineer — Sh.Arun kumar
5. Name of Assistant Engineer — Sh. Subhash sharma
6. Name of Executive Engineer — Sh. Anil Aggarwal
7. Name of Contractor/ Agency — M/S Shri Bhagwan Construction Co.
8. Name of Officer collecting sample — Sh. Subhash Sharma
9. Date of collection — 6/3/17
10. Date of testing — DSK
11. Identification Mark — 75
12. Class Designation — 5.00Nos + 5.00Nos.
13. No of specimen sent for testing

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked sealed has/have been taken in my presence which represent 5000 quantity of work/supply made at site/store.

Signature of AE In charge of work

Signature of Contractor

Signature of Officer taking sample (EE/AE)

Part –II

TEST REPORT

NO. SE(QC)/AE(Lab)/2016-17/D- 4850 Date. 28/03/17

Test no. 2567 date. 9.3.17

Date of Receipt 9.3.17

(A) WATER ABSORPTION

S.no	DRY WEIGHT (GMS)	WET WEIGHT (GMS)	WATER ABSORBED (GMS)	%AGE -WATER ABSORBED.	AVERAGE WATER ABSORBED IN %AGE
1	2920	3277	357	12.23	12.84
2	2890	3260	370	12.80	
3	3069	3452	383	12.48	
4	2871	3222	351	12.22	
5	3073	3518	445	14.48	

ACCEPTABLE

EFFLORESCENCE: Date Of Testing upto: 28.3.17

ACCEPTABLE

Efflorescence observed: NIL/ Slight/ Moderate/Heavy

Only testing has been conducted in this laboratory. The sample/ samples has/have been collected and handed over by the field staff of the concerned division.

28/3/17

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO.

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to-

1 EE/C-4

2 AL