

The Assistant Engineer (QC)
Quality Control Lab DUSIB
Vikas kutir ITO New Delhi

R. No C 1981

RECEIVED 06 JAN 2017

Part -I

Dispatch No: 35 AE-I/EEC-4/DUSIB/2016-17

Date 06/01/2017

Sub: Testing of Bricks/Brick tiles for Dimension/Compressive Strength

W.O.NO : AL -12/ EE-C-4/2016-17/D-220

Date 19.05.2016

1. Name of work : JSC OD Free

S.H : Up gradation / Renovation JSC in JJ Cluster Chunna Bhattie Lakkar Mandi Kirti Nagar(PID-6234)

2. Detail from where sample as collected

from the site

3. Name of circle Division

2/ C-4

4. Name of Junior Engineer

D.P.MEENA

5. Name of Assistant Engineer

Sh. S.C.Gaur

6. Name of Executive Engineer

Sh. ANIL AGGARWAL

7. Name of Contractor/ Agency

M/s YOGESH TYAGI

8. Name of Officer collecting sample

Sh. S.C.Gaur

9. Date of collection/Date of filling frog

1.01.2017 / 2.01.2017

10. Date of testing

06.01.2017

11. Identification mark

SAGAR

12. Class designation

75

13. no. of specimen sent for Testing

5.00 Nos

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked.....has/have been taken in my presence which represent quantity of work/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part -II

TEST REPORT

NO. SE(QC)/AE(Lab)/2016-17/D-

Test no. 198 date 6.1.17

Date.

10/1/17

Date of Receipt 6.1.17

Date of testing 6.1.17

S.no	Dimensions			Maximum Strength Failure (T)	Compressive Strength Failure (kg./ sq.cm)	Average strength kg/sq.cm)
	Length (cms)	width (cms)	Area (sq.cm)			
1	21.60	11.00	237.60	22.00	92.59	92.83
2	21.60	10.80	233.28	21.00	90.02	
3	21.80	10.70	233.26	22.00	94.31	
4	22.00	10.60	233.20	21.50	92.19	
5	22.00	11.00	242.00	23.00	95.04	

DIMENSION TEST FOR 20 BRICKS

1. Length

2. Width

3. Height

NOT ASKED FOR

Tested in my presence

Only testing has been conducted in this laboratory. The samples has have been collected cured and handed over by the field staff of the concerned division.

Copy to

1. EE/C-4
2. cl

Assistant Engineer (QC Lab)
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
30th. of S.C.T. of Delhi
ITO, New Delhi-02