

R.NO: 2016

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer. ITO, New Delhi

RECEIVED 13 JAN 2017

Part I


AL No. 109/WP/US41/321/13/AEE/Date BC-4/DUSIB/2016/16.11.17
Sub: Testing of Bricks / Bricks Tiles for Compressive Strength / Dimension D-9070/16.11.


1. Name of work: Pay and Use ISC
Sub Head: Upgrading/renovation of 60 seater conventional ISC in JJC D-block
kusumpur pahari, Vasant Kunj.


Project ID 6040

2. Details from where sample is collected: from site
3. Name of Circle / Division: Circle-2/C-4
4. Name of Junior Engineer: Sh. Harish Chauhan...
5. Name of Assistant Engineer: Sh. Birender Chauhan
6. Name of Executive Engineer: Sh. C.P. Singh
7. Name of Contractor / Agency: Sh. Mukesh Kumar Goyal
8. Name of Officer Collecting Sample: Sh. Birender Chauhan
9. Date of collection / Date of filling frog: :8.1.17/9.1.17
10. Date of testing: :13.1.17
11. Identification Mark: KBF
12. Class Designation: 75
13. No. of specimen sent for testing: 5

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked ..KBF.....has / have been taken in my presence which represent ..15.0.0.0..... quantity of work / supply made at site / store.


Signature of J.E.


Signature of Contractor


Signature of Officer
Taking sample (EE / AE)

Part II

No. SE(QC/AE(Lab)/2016-17/D-3055

Test No. 2016 Date 13.1.17

Date of Receipt 13.1.17

Date 13.1.17

(A) COMPRESSIVE STRENGTH


S.No.	Length Cms	Breadth Cms	Area Sq Cms	Crushing Load (In MT)	Compressive Strength (In Kg / Cm ²	Average Compressive Strength
1.	22.00	10.50	231.00	21.00	90.91	90.76
2.	21.90	10.50	229.95	20.00	86.97	
3.	22.10	10.60	233.20	22.00	94.33	
4.	21.50	10.50	225.75	20.00	88.59	
5.	21.50	10.50	225.75	21.00	93.02	

Date of testing

(B) DIMENSION

upto.....

Only testing has been conducted in this laboratory, the sample have been collected, cured and handed over by the field staff of the division.


13/1/17
Assistant Engineer (QC) Lab.
DUSIB
Delhi Urban Sanitation Improvement Board
30m of S.C.T. of Delhi
ITO, New Delhi-02

Copy to:

1. EE/C-4

2. dc