

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R No. 310

RECEIVED 04 MAY 2017

Part IDispatch No. D-229/EE/C-6/DUSIB/17-18Date: 3/5/17

Sub: Testing of CC cubes of mix M-15 for 7/28 days Compressive Strength.

- A. L. No. 74/WJ-6981/(81)/EE/C-6/DUSIB/2015-16/D-2786 Dt.:18.03.2016
- Name of work: E.I.U.S. (B/F & Drain)
SH: Providing and laying cc pavement and drains in deteriorated lanes of jj cluster at Sanjay Colony Okhla Ind. Area Phase-II.
 - Details from where sample is collected From the Site of work-----
 - Name of Circle/Division Circle II/C-6 -----
 - Name of Junior Engineer Sh. Ramesh Kumar-----
 - Name of Assistant Engineer Sh. Deepak Kumar Behl-----
 - Name of Executive Engineer Sh. O.P. Pruthi -----
 - Name of Contractor/Agency M/S Raj Builder -----
 - Name of Officer collecting sample: Sh. Deepak Kumar Behl-----
 - Date of collection: 5-4-17-----
 - Date of testing: 4-5-17-----
 - Required strength: As per CPWD Specification, -----
 - No. of specimen sent for testing: --03-----
 - Size of specimen: 15 X 15 X 15 cm-----
 - Mark of specimen: ---A-----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked---A-----has/have been taken in my presence which represent 30 m3 approx quantity of works/supply made at site/store.

Nmmr
Signature of JE
In charge of work

[Signature]
Signature of Contractor

[Signature]
Signature of Officer
taking sample (AE/EE)

Part II**TEST REPORT**

No. SE(QC)/AE(Lab.)/2017-18/D-

Date:

Test No. 316 Date: 4.5.17

Date of Receipt: 4.5.17

Date of testing: 4.5.17

Concrete Mix: M-15

Days test: 28/29 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8014	225	46.00	177.78	188.15	
2.	8101	225	45.00	200.00		
3.	8056	225	42.00	186.67		

Nmmr
Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

[Signature]
Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Board
Govt. of C.T. of Delhi
17C, New Delhi-02

Copy to:-

- EE/C-6
- o/c

EE May
Correlati
According