

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R. No. 2135

RECEIVED 27 JAN 2017

Part I

Dispatch No. EE/C-11/DUSIB/17/D-92

Date: 25/01/17

Sub: Testing of CC cubes of mix M25 for 7/28 days Compressive Strength.

A. L. No. F1WC144501AAQ/A1-20/ComEEG1/DUSIB/16-17 Date: 4.10.2016

1. Name of work: Pay & use up gradation of 60 Smt. JSC in WC
SH: Kalander Colony (Block-C) Nr. Bhalswa Dairy

2. Details from where sample is collected
3. Name of Circle/Division
4. Name of Junior Engineer
5. Name of Assistant Engineer
6. Name of Executive Engineer
7. Name of Contractor/Agency
8. Name of Officer collecting sample
9. Date of collection:
10. Date of testing:
11. Required strength:
12. No. of specimen sent for testing:
13. Size of specimen:
14. Mark of specimen:

From Site
C-4 C-11
N.K. MANGHANI
M.K. GARG
SH. AJAY
M.C. MIKESH KUMAR GOYAL
M.K. GARG
28.12.2016
25-01-2017 (27.1.17)
250 kg/cm²
03 Nos
15cm x 15cm x 15cm
M.K.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked M.K. has/have been taken in my presence which represent 2017 quantity of works/supply made at site/store.

Signature of AE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2016-17/D-
Test No. 2135 Date: 27.1.17

Date: 27/1/17

Date of Receipt: 27.1.17

Date of testing: 27.1.17

Concrete Mix: M-25

Days test: 28/30 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8214	225	67.00	297.78	291.85	
2.	8196	225	68.00	302.22		
3.	8214	225	62.00	275.56		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Copy to:-

1. EE/C-11
2. CL

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02