The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer. ITO, New Delhi

R. No. 2366
RECEIVED 16 FEB 2017

Part I
No. AL-07/30/EEC-1/2015-16/D. Date-15/2/17 Date..18-5-16....

Sub: Testing of Bricks / Bricks Tiles for Compressive Strength / ~~Dimension~~

AL. No WA/4222/AL No 7/EEC-1/2016-17/D-370 DL 18.5.16

1. Name of work: (E.I.U.S) Environment Improvement in Urban Slums.

Sub Head: Providing and cement concrete Flooring and construction of Drain in the lans of JJ cluster Indira camp No 5 Vikashpuri (PJ ID 000006798)

2. Details from where sample is collected: ..... At Site .....
3. Name of Circle / Division: ..... C-1 .....
4. Name of Junior Engineer: ..... T.P. Thakur .....
5. Name of Assistant Engineer: ..... A.K. Nasha .....
6. Name of Executive Engineer: ..... Sh. P.K. Singh .....
7. Name of Contractor / Agency: ..... M/S Durga Constru
8. Name of Officer Collecting Sample: ..... AK Nasha .....
9. Date of collection / Date of filling frog: ..... 11.02.17 / 12.02.17
10. Date of testing: ..... 16.2.17 .....
11. Identification Mark: ..... [illegible] .....
12. Class Designation: ..... C.D. 75 .....
13. No. of specimen sent for testing: ..... 5 Nos .....

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked .....has / have been taken in my presence which represent ..... quantity of work / supply made at site / store.

Signature of J.E. Signature of Contractor Signature of Officer Taking sample(EE / AE)

Part II

No. SE(QC)/AE(Lab)/2006/D- 4365 Date...17/02/17.....

Test No...2366.....Date..16.2.17. Date of Receipt....16.2.17.....

(A)COMPRESSIVE STRENGTH Date of testing upto..16.2.17...

S.No.	Area (Sqcm)	Crushing Load (In MT)	Compreesive Strength (In Kg / Cm2	Average Compressive Strength
1.	23.00 × 11.00 253.00	24.00	94.86	92.00
2.	22.50 × 11.20 252.00	25.00	99.20	
3.	22.80 × 11.00 = 250.80	23.00	91.70	
4.	22.50 × 11.00 247.50	22.50	90.90	
5.	22.70 × 11.10 = 251.97	21.00	83.34	

(B) DIMENSION Date of testing upto.....

Not Asked for

Only testing has been conducted in this laboratory, the sample have been collected, cured and handed over by the field staff of the division.

16/2/17

Assistant Engineer (QC) Lab.
DUSIB, Vikas Kuteer, ITO.

Copy To:-
1. EE/C-1
2. O/C