

R.No 2378
RECEIVED 17/2/17

The Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Vikas Kutir, ITO- New Delhi.
PART-I Not D-1381/EEC-5/2017
A. L. No. 02/WH/4945/ EE C-5/DUSIB/2016-17/D-28

Dt 17-02-17

Dated: 06.04.2016

Sybject:- Testing of CC Cubes of mix M-15 for 7/28 days compressive strength.

Name of work :- P/L CC Pavement and repair of drains in JJC Shastri Market Moti Bagh South.

- | | |
|---|---------------------------------|
| 1. Details from where sample is collected:- | From Site of work |
| 2. Name of Circle / Division:- | Circle-II /C-5 |
| 3. Name of Junior Engineer:- | ----- |
| 4. Name of Assistant Engineer :- | Sh. S.K. Mittal |
| 5. Name of Executive Engineer :- | Sh. S.K.Varshney |
| 6. Name of Contractor / Agency:- | DK Construction Co. |
| 7. Name of officer collecting sample:- | ----- |
| 8. Date of collection :- | 20-1-17 |
| 9. Date of testing :- | 17-2-17 |
| 10. Identification mark :- | |
| 11. Size of specimen :- | 150 x 150 x 150 mm ³ |
| 12. No. of Specimen sent for testing:- | 3 Nos. |
| 13. Required strength :- | 150 kg/cm ² |

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (s) marked.....has / have been taken in my presence which representquantity of work / supply made at site.

Signature of JE

Signature of contractor

Signature of AE /EE

PART-II

TEST REPORT

No. SE (QC) /AE (Lab) / 2011 /D- 4380
Test No. Date 2378
Date of Receipt 2378 dt 17/2/17
Date of Testing :- 17.2.17
Concrete Mix :- M-15

Date:- 20/02/17

Day test :- 28 days

S.No	Weight of specimen (Gms)	Area in Sqm.	Compressive Strength Load Comp. strength (Tones) (Kg./sq.cm)	Average strength Kg./sqcm.	Remarks
1	7990	225	41.00	182.22	182.96
2	8061	225	42.00	186.67	
3	7938	225	40.50	180.00	

Tested in my presence

Only testing has been conducted in this laboratory. The sample(s) has / have been collected and handed over by the field staff of concerned division.

Copt to.
1. E.E /C-5
2. O/C

Assistant Engineer (QC) Lab./ DUSIB
ITO, New Delhi-02