

The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kuteer. ITO, New Delhi

R. No. 2007
RECEIVED 13 JAN 2017

Part I

No. WF/4513/AE-II (Site)/DDI/2016-17/D-1/3)

Date. 13-1-17

Sub: Testing of CC cubes of mix M-25 for 7/28 days Compressive Strength.

AL. No: WF/4733(1)/EEC-2/AI.no 01/2016-17/D-26 dt. 18.04.2016

1. Name of work: C/o 7620 five storeyed low cost housing (under JNNURM) for slum dweller at savda Ghewra Ph-III

Sub Head: C/o purposed primary school at Savda Ghewra Ph-III (Site-I) near Block-F

2. Details from where sample is collected: From Site. *Near Fire Station*
3. Name of Circle / Division: I/C-2
4. Name of Junior Engineer:
5. Name of Assistant Engineer: Sh. Rajiv Dhawan & Sh. K.L Suneja
6. Name of Executive Engineer: Sh. S.C. Sharma
7. Name of Contractor / Agency: M/S D.R. Builders
8. Name of Officer Collecting Sample: *Sh. S.C. Sharma EE/I*
9. Date of collection: *16/12/2016*
10. Date of testing: *13/01/2017*
11. Required Strength: *31.5 MPa*
12. No. of specimen sent for testing: *3 nos*
13. Size of specimen: *150 X 150 X 150 mm*
14. Mark of specimen: *Snip. of 56.11*

Specimen relating to work mentioned above is / are sent for testing. It is certified that the sample (s) marked *Snip. of 56.11* has / have been taken in my presence which represent *2.7 m cum* quantity of work / supply made at site / store.

Signature of A.E.

Signature of Contractor

Signature of Officer
Taking sample (EE / AE)

Part II

No. SE(QC)/AE(Lab)/2016/D-3049

Test No. 2007 Date. 13.1.17

Date of Testing. 13.1.17

Concrete Mix M-25

Date. 13/1/17
Date of Receipt.

Day Test. 28 days

| S. No | Wt. of specimen (In gms.) | Area (In Sq. cm.) | Compressive Strength | | Average Strength (In Kg/sq.cm) | Remarks |
|-------|------------------------------|----------------------|----------------------|---------------------------------|-----------------------------------|------------------------------|
| | | | Load (Tonnes) | Comp. strength (In Kg/sq.cm) | | |
| 1. | 8156 | 225 | 64.00 | 284.44 | 299.26 | EE May Correlate Accordingly |
| 2. | 8224 | 225 | 70.00 | 311.11 | | |
| 3. | 8189 | 225 | 68.00 | 302.22 | | |

Tested in my presence

Only testing has been conducted in this laboratory. the sample have been collected, cured and handed over by the field staff of the concerned division.

Copy To:

1. EE/I

Assistant Engineer (QC) Lab