

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R No. 0203

RECEIVED 24 APR 2017

Date: 24/04/17

Part I

Dispatch No. AE-II/C12/DUSIB/17/D-63

Sub: Testing of CC cubes of mix 1:1.5:3 for 07 days Compressive Strength.

AL No. 37/WK/7205(125)/EEC-12/DUSIB/2016-17 /D- 998 dated 24.11.2016:

NOW: Pay and Use JSC SH: Construction of 2 nos. Complexes with Platform, Septic tank and its disposal at different location for 20WCs each at JJ Cluster near Railway Colony Shakur Basti (For Cubicals).

(P.I.D. 7103)

- 1 Details from where sample is collected From Site
- 2 Name of Circle/Division Circle-4/C-12
- 3 Name of Junior Engineer _____
- 4 Name of Assistant Engineer A.K. Sardana
- 5 Name of Executive Engineer Sh. K.K. Sharma
- 6 Name of Contractor/Agency M/S M3S Construction Co.
- 7 Name of Officer collecting sample A.K. Sardana
- 8 Date of collection: 17/4/2017
- 9 Date of testing: 24/4/2017
- 10 Required strength: _____
- 11 No. of specimen sent for testing: 03
- 12 Size of specimen: 15X15X15 cm
- 13 Mark of specimen: (X)

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/samples marked- (X) -----has/have been taken in my presence which represent-----quantity of works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (JE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2016-17/D-

Test No. 0203 Date: 24.4.17

Date of Receipt: 24.4.17

Date of testing: 24.4.17

Concrete Mix: 1:1.5:3

Date:

Days test: 7 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8213	225	42.00	186.67	183.70	
2.	8315	225	43.00	191.11		
3.	8274	225	39.00	173.33		

EE May
Correlate
Accordingly

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

Copy to:-

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02