

To,

The Assistant Engineer (QC)  
Quality Control Lab, DUSIB  
Vikas Kutir, ITO, New Delhi

R-NO-1930  
RECEIVED 30 DEC 2016

Part I

No. D-37/AE-I/C-7/2016 Date: 29/12/16  
ALN-6031/42/PG/EE C-7/2016-17/D-788 dated 22-9-16

Sub: Testing of Bricks/Bricks Tiles for Water Absorption/Efflorescence.

- Name of work: Pay and Use JSC.  
Sub-Head :- Contt. of 20 Secs JSC of JTC Dr. Amalakar Comb. Co. Ltd.  
(DSD-7124)

Acceptance Letter No. : WI/6031/42/PG/EE C-7/2016-17/D-788 dated : 22-9-16

- Detail from where sample is collected: Above noted work.
- Name of Circle/Division: Circle-III, C-7
- Name of Junior Engineer: Sh. Sunil Meena
- Name of Assistant Engineer: Sh. K.L. Meena
- Name of Executive Engineer: Sh. K.B. Sharma
- Name of Contractor/Agency: M/s Global Associates
- Name of Officer collection sample : Sh. K.L. Meena
- Date of collection/Date of filling frog: 26-12-16
- Date of Testing: .....
- Identification Mark: RBH
- Class designation: 7.5
- No. of specimen sent for testing: 10

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked R.B.H. has/have been taken in my presence which represent 20 Secs quantity of work/supply made at site/store.

Signature of JE Meena Signature of Contractor Global Signature of Officer taking sample (EE/AE) Meena  
In-charge of work

Part II TEST REPORT

No. SE (QC)/AE (Lab)/2016/D- 413 Date : 19/11/17  
Test No. 1930 Date 30.12.16  
Date of Receipt 30.12.16  
Date of Testing 30.12.16

(A) WATER ABSORPTION Day of Testing upto 31.17

S. No.	Dry Wt. (gms)	Wet Wt.(gms)	Water Absorbed (gms)	%age water Absorbed	Average absorption water
1.	2466	2823	357	14.47	<b>ACCEPTABLE</b>
2.	2569	2909	340	13.23	
4.	2489	2861	372	14.94	
5.	2381	2877	376	15.77	
	2410	2762	352	14.57	

(B) EFFLORESCENCE SLIGHT Dt. Of testing upto: 19.1.17

Only testing has been conducted in this laboratory. the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to:  
1. EE/C-7  
2. etc

Assistant Engineer (QC) Lab.  
DUSIB, Vikas Kutir, ITO  
Assistant Engineer (QC)  
North Urban Services Department Board  
30, Vikas Kutir, ITO, New Delhi  
110066