

The Assistant Engineer (QC)  
Quality Control Lab DUSIB  
Vikas kutir ITO New Delhi

R. No: 1987  
RECEIVED 06 JAN 2017

**Part -I**

Dispatch No: 31/AE-III/EE/C-4

Date: 04/01/17

Sub: Testing of RMC M10 for 28 days Compressive Strength

No. AL-120/WD/4541/319/40/AE-III/EE-C-4/16-17/D-955

Date 22/11/2016

**1. Name of work : Pay and Use (JSC)**

S.H : Boring of tubewell at 101 seater JSc at Chander Sekhar Azad Colony Wazirpur (Project ID 000007128)

**2. Details from where sample as collected**

3. Name of circle Division
4. Name of Junior Engineer
5. Name of Assistant Engineer
6. Name of Executive Engineer
7. Name of Contractor/ Agency
8. Name of Officer collecting sample
9. Date of collection
10. Date of testing
11. Required strength
12. No of specimen sent for testing
13. Size of specimen
14. Mark of specimen

**Form the site**

Circle -2 / C-4  
Sh. Ayush Goyal  
Sh. S.C.Gaur  
Sh. Anil Aggrwal  
M/S YOGESH TYAGI.  
Sh. S.C.Gaur  
8/12/2016  
5.01.17  
RMC M10  
3 Nos  
15cmx15cmx15cm

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked 30 has/have been taken in my presence which represent 30 cum quantity of work/supply made at site/store.

Signature of JE  
In charge of work

Signature of Contractor

Signature of Officer  
taking sample (AE-III/C-4)

**Part -II**

**TEST REPORT**

NO. SE(QC)/AE(Lab)/2016-17/D- 3029

Date: 10/1/17

Test no. 1987 date. 6.1.17

Date of Receipt 6.1.17

Date of testing 6.1.17

Concrete Mix: M-10

Days test: 28/29 days

S.no	Wt of specimen in gms	Area in sq.cm	Compressive strength		Average strength( kg/sq.cm )	Remarks
			Load strength (Tonnes)	comp. ( kg./ sq.cm)		
1	7896	225	30.00	133.33	134.81	EE May Correlate Accordingly
2	7918	225	31.00	137.78		
3	7923	225	30.00	133.33		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/ samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)

DUSIB, Vikas Kutir, ITO