The Assistant Engineer (QC) Quality Control Lab DUSIB Vikas kutir ITO New Delhi

Part -I

Dispatch No: AE-1/C-4/DUSIB/2016-17/D-...3.6.8....

Sub: Testing of R.M.C. cubes of mix M-15/ CC grade for 7/28 days Compressive Strength

No. AL- AL-122/WD/4541/318/162/AE-1/EEC-4/2016-17/D - 960

Dt:- 23.11.2016

1. Name of work: EIUS

S.H.: Providing and laying C.C.Pavement and drainage System i/c storm water drainage in JJ Cluster Amar Park Zhakira (Near Zhakira Chowk), Moti Nagar, AC-25.(PID-7269)

2. Details from where sample as collected

3. Name of circle Division

4. Name of Junior Engineer

5. Name of Assistant Engineer

6. Name of Executive Engineer

7. Name of Contractor/ Agency

8. Name of Officer collecting sample

9. Date of collection

10. Date of testing

11. Required strength

12. No of specimen sent for testing

13. Size of specimen

14. Mark of specimen

Form the site

Circle -2 / C-4

D.P.MEENA

Sh. S. C. Gaur

Sh. Anil Kumar Aggarwal

M/s Yogendera & Co..

30/01/2017

27/02/2017

3 nos

15cmx15cmx15cm

mas Hay Specimen relating to work mentioned above is/are sent for testing. It is certified that the quantity of work/supply made at site/store.

Signature of JE

Signature of Contractor

Signature of Officer taking sample AC

In charge of work (EE/AE)

Part -II

TEST REPORT

NO. SE(QC)/AE(Lab)/2016-17/D. 4479

Test no. 9454 date. 27.2.17 Date of Receipt 27.2.17

Date of testing 27.2.17

Date. 27 02 17

S.no	Wt of Asea in so so		Days test: 28 days			
	specimen in	Area in sq.cm	Load (Tonnes)	comp. strength (kg./ sq.cm)	Average strength(kg /sq.cm)	Remarks
}	7956	225	40.50	180.00	185.93	
2	8031	225	42.00	186.67		
3	8064	225	43.00	191.11		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/ samples has/have been collected and handed over by the field staff of the concerned division.

> Assistant Engineer (QC-Lab) DUSIB, Vikas Kutir, ITO

1 EE

Osini Urban Nasharin proviement Board Box, wi x.c. 1, a feetu IRO are Telesion