To RECEIVED \$9 MAR 2017 The Assistant Engineer (QC) Quality Control Lab., DUSIB Vikas Kutir, ITO, New Delhi Part I - Date: 29/3/17 Dispatch No. Sub: Testing of CC cubes of mix M-15 for 28 days Compressive Strength. A. L. No. AL-59/WH/4945/EE C-5/DUSIB/2015-16/D-1360 (PID 000006800 Name of work:-EIUS SH: P/L CC Pavement and repair of drains in JJC Parvatiya Camp Sec-IV, RK Puram 2. Details from where sample is collected -----from site-------Circle-II, Div: C-5-----3. Name of Circle/Division 4. Name of Junior Engineer Sh. S.K. Mittal-5. Name of Assistant Engineer ----Sh.S.K. Varshney-----6. Name of Executive Engineer ----M/s S.S. Constructions Co.----7. Name of Contractor/Agency ---- Sh. S.K. Mittal ---8. Name of Officer collecting sample 2.8(2/17 9. Date of collection: 10. Date of testing: 11. Required strength: 12. No. of specimen sent for testing: 15X15X15 cm-13. Size of specimen: 14. Mark of specimen: Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ Samples marked A-----has/have been taken in my presence which represent-----quantity Of works/supply made at site/store. Signature of Officer, Signature of Contractor Signature of JE taking sample (EE/AE) In charge of work TEST REPORT Part II Date: 28 03 17 No. SE (QC)/AE (Lab.)/2016-17 /D- 4873 2815 Date: 29.3.17 Test No. Date of Receipt: 29.3.17 Date of testing: 29.3.17 Days test: 28 29day Concrete Mix: Average Strength Remarks Compressive Strength Area in Wt. of specimen S. No (Kg./sq.cm) Comp. strength Load sq.cm. in gms (Kg./sq.cm) (Tonnes) 191.11 4300 1. 225 8170 184.44 41.50 225 8094 2. 191.11 4300 225 8191

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

DUSIB, Vikas Kutir, ITO

Copy to:-