

The Assistant Engineer (QC)
Quality Control Lab DUSIB
Vikas kutir ITO New Delhi

R. NO : 1975
RECEIVED 06 JAN 2017

Part -I

Dispatch No: 35/AE-III/EE/C-4

Date: 06/1/17

Sub: Testing of RMC M15 for 7/28 days Compressive Strength

No. WD/4541/319(44)/AE-III/EE-C-4/DUSIB/16-17/D-725

Date 27/09/16

1. Name of work : E.I.U.S.

S.H : C/O S.W. Drain and C.C. pavement in JJC B-46/2 Wazirpur Industrial area Wazirpur

2. Details from where sample as collected

Form the site

3. Name of circle Division

Circle -2 / C-4

4. Name of Junior Engineer

Sh. Ayush Goyal

5. Name of Assistant Engineer

Sh. S.C.Gaur

6. Name of Executive Engineer

Sh. Anil Aggarwal

7. Name of Contractor/ Agency

M/S Bhardwaj Associates.

8. Name of Officer collecting sample

Sh. S.C.Gaur

9. Date of collection

05/12/2016

10. Date of testing

06/01/2017

11. Required strength

RMC M15

12. No of specimen sent for testing

3 Nos

13. Size of specimen

15cmx15cmx15cm

14. Mark of specimen

Dated signature

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked Sealed has/have been taken in my presence which represent 20 cum quantity of work/supply made at site/store.

Signature of JE

Signature of Contractor

Signature of Officer
taking sample (AE-III/C-4)

In charge of work

Part -II

TEST REPORT

NO. SE(QC)/AE(Lab)/2016-17/D- 3020

Date: 10/1/17

Test no. 1975 date: 6.1.17

Date of Receipt 6.1.17

Date of testing 6.1.17

Concrete Mix: M-15

Days test: 28/32 days

S.no	Wt of specimen in gms	Area in sq.cm	Compressive strength		Average strength(kg/sq.cm)	Remarks
			Load strength (Tonnes)	comp. (kg./ sq.cm)		
1	8061	225	44.00	195.56	194.08	Average strength is 194.08 kg/sq.cm. All test results are in accordance with the required strength of 15 kg/sq.cm.
2	8014	225	42.00	186.67		
3	8067	225	45.00	200.00		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/ samples has/have been collected and handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)

DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)

Delhi Urban Shelter Improvement Board

Govt. of N.C.T. of Delhi

ITO, New Delhi-02

Copy To

1 EE/C-4