

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R. No: ~~1017~~ 1993

Received on 10-1-17

Part I

Dispatch No 82/AE-VIII/C-11 D.U.S.I-B/16-17 Date: 10/1/17

Sub: Testing of CC cubes of mix M-15 for 7/28 days Compressive Strength.

A. L. No. P/WC/144501AAQ/AL-15/CM/EEC-4/DUSIB/2016-17 Date: 10-9-16

1. Name of work:-

SH:

2. Details from where sample is collected

3. Name of Circle/Division

4. Name of Junior Engineer

5. Name of Assistant Engineer

6. Name of Executive Engineer

7. Name of Contractor/Agency

8. Name of Officer collecting sample

9. Date of collection:

10. Date of testing:

11. Required strength:

12. No. of specimen sent for testing:

13. Size of specimen:

14. Mark of specimen:

10707
Date: 16-9-16
15. center 10-10-16
ISC in use opposite 656 Maya f 10-16
K-BLK Janghon gir puri
From Site
C-4 C-11
N.K. MENGHANI
M.K. GARG
S.H. AJAY
S.H.M. K. GOYAL
M.K. GARG
09-12-2016
10-01-2017
150 kg/cm²
03 nos
15cm x 15cm x 15cm
M.K.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked M.K. has/have been taken in my presence which represent 28 nos quantity of
works/supply made at site/store.

Signature of JE
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2016-17/D- 1993 3034

Date: 10/1/17

Test No. 1993 Date: 10-1-17

Date of Receipt: 10-1-17

Date of testing: 10-1-17

Concrete Mix: M-15

Days test: 28/32 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	8023	225	44.50	197.78	193.33	EE May Correlate Accordingly
2.	7956	225	43.00	191.11		
3.	7898	225	43.00	191.11		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

Copy to:-

1. EE/C-11

2.

O/C

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02