

R.No. 0074
RECEIVED 12 APR 2017

The Assistant Engineer (QC)
Quality Control Lab DUSIB
Vikaskutir ITO New Delhi

Part-I

Dispatch No: AE-IV/C-4/DUSIB/2017-18/D-1..... Date 11-4-17
SUB : Testing of CC Cube Mix 1: 1.5: 3 after 28 days curing for compressive strength.
No. AL-80/WD/4541/319/16/AE-III/EE-C-4/DUSIB/2016-17/D-788 Date 17-10-2016

1. Name of work: JSC Pay and Use
Sub Head: Construction of 40 Seater Conventional / semi pucca JSC at JJ Basti Mahatma Gandhi Camp road
No. 77 Punjabi Bagh Site-I.

P.I.D 7440

2. Details from where sample as collected
3. Name of circle Division
4. Name of Junior Engineer
5. Name of Assistant Engineer
6. Name of Executive Engineer
7. Name of Contractor/ Agency
8. Name of Officer collecting sample
9. Date of collection
10. Date of testing
11. Required strength
12. No of specimen sent for testing
13. Size of specimen
14. Mark of specimen

Form the site
Circle -2 / C-4
PradeepAgrawal
Sh.Yashvir Singh
Sh. Anil Kumar Aggarwal
M/S Shri Bhagwan Construction Co
Sh. Yashvir Singh (AE-IV)

15-3-17
12-4-17

3 nos
15cmx15cmx15cm

NO. 150 & Dt.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked No. 150 has/have been taken in my presence which represent 50 cum quantity of
work/supply made at site/store.

Signature of JE
in charge of work

Signature of Contractor

Signature of Officer
taking sample (AE/AT)

Part-II TEST REPORT

NO. SE (QC)/AE (Lab)/2016-17/D-010
Test no. 0074 Date 12-4-17
Date of Receipt 12-4-17
Date of testing 12-4-17
Concrete Mix: 1:1.5:3

Date. 18/04/17

Days test: 28 days

S.no	Wt of specimen in gms	Area in sq cm	Compressive strength		Average strength (kg /sq.cm)	Rema (kg)
			Load (Tonnes)	comp strength (kg / sq cm)		
1	8248	225	60.50	268.89	285	
2	8421	225	68.00	302.22		
3	8370	225	64.00	284.44		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been taken by the field staff of the concerned division.

EE May Correlate Accordingly

Assistant Engineer (QC) Lab
Vikaskutir-40
Delhi Urban Shelter Improvement Board
Secy of A.C.T., of Delhi
ITO, New Delhi-02

Copy To

1. EE/C-4

OIC