

1D 00000 7836

To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

RNO 0501
RECEIVED 26 MAY 2017

Part IDispatch No. D-198/EEC-5/2017Date: 26-05-17

Sub: Testing of CC cubes of mix M 15 for 28 days Compressive Strength.

A. L. No. AL-83 /WH/ 4945/EE-C-5/DUSIB/ 2016-17 /D-1318 Dated. 08.02.2017

Name of work: EIUS

SH: -P/L CC Pavement and repair of drains in JJC Bhanwar Singh Camp D-Block Vasant Vihar.

1. Details from where sample is collected	-----Site -----
2. Name of Circle/Division:	-----II/EE-C-5 -----
3. Name of Junior Engineer:	Sh. -----
4. Name of Assistant Engineer:	Sh. S.K. Mittal-----
5. Name of Executive Engineer:	Sh. S.K. Varshney-----
6. Name of Contractor/Agency:	Sh. Devender Kumar Sharma-----
7. Name of Officer collecting sample:	Sh. S.K. Mittal-----
8. Date of collection:	<u>28/4/17</u> -----
9. Date of testing:	<u>26/5/17</u> -----
10. Required strength:	<u>180</u> -----
11. No. of specimen sent for testing:	--3 Nos. -----
12. Size of specimen:	15 X 15 X15 cm-----
13. Mark of specimen:	<u>(A)</u> -----

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/
samples marked (A)-----has/have been taken in my presence which represent 203 quantity
of works/supply made at site/store.

Signature of J.E
In charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part IITEST REPORTNo. SE(QC)/AE(Lab.)/2017-18 /D- 0574Date: 29/05/17Test No. 0501 Date: 26.5.17Date of Receipt: 26.5.17Date of testing: 26.5.17Concrete Mix: M-15Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength (Kg./sq.cm)	Remarks
			Load (Tonnes)	Comp. strength (Kg./sq.cm)		
1.	7894	225	41.00	182.22	185.19	EE May Correlate Accordingly
2.	8036	225	42.00	186.67		
3.	8001	225	42.00	186.67		

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and
handed over by the field staff of the concerned division.

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir, ITO
Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Sohni, C.T., of Delhi
ITO, New Delhi-42

Copy to:-

1. EE/C-52. dc