

To,
The Assistant Engineer (QC)
Quality Control Lab, DUSIB
Vikas Kutir, ITO, New Delhi

R.No. 2407
RECEIVED 21 FEB 2017

Part I
No. D.1061/44/c-70/DUSIB Date: 18/2/17
Sub: Testing of CC cubes of mix RMC M15 for 28 days compressive strength
W.O.No.: WG/4321/AL-62/EEC-10/2016-17/934 dated 12/01/2017

1. Name of work:- EIUS
S.Head:- P/L CC pavement on deteriorated lanes in JJ Cluster at Block-Z, Naraina Industrial Area in PH-I (Project ID 8068)
2. Detail from where sample is collected: Site
3. Name of Circle/Division: Circle-4, ~~PH-I~~ C-10
4. Name of Junior Engineer: Ashwani Kumar NIL
5. Name of Assistant Engineer: Ashwani Kumar
6. Name of Executive Engineer: Shyam Singh
7. Name of Contractor/Agency: M/S J.D. Construction
8. Name of Officer collection sample: Ashwani Kumar
9. Date of collection: 24.01.2017
10. Date of Testing: 21.02.2017.....
11. Required Strength: ...15 N/mm2.....
12. No. of specimen sent for testing:3 Nos.....
13. Size of specimen:15X15Cm.....
14. Mark of Specimen:Sign. By AE.....

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked Sign. By AE has/have been taken in my presence which represent...20 Cum.... quantity of work/supply made at site/store.

B. B. Gupta
Signature of Contractor

Ashwani Kumar
Signature of Officer
taking sample (AE)

Part II TEST REPORT

No. SE (QC)/AE (Lab)/2011/D- 4433 Date: 23/02/17
Test No. 2407 Date 2
Date of Receipt 21.2.17
Date of Testing 21.2.17
Concrete Mix M-15 Day test 28 days

S. No.	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength		Average Strength Kg/sq.cm	Remarks
			Load (Tonnes)	Comp. strength (Kg/sq.cm)		
1.	7936	225	41.00	182.22	185.93	See May Corrected Accordingly
2.	7988	225	42.00	186.67		
3.	8069	225	42.50	188.89		

Tested in my presence Ashwani Kumar

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the filed staff of the concerned division.

Copy to:
1. EE, C-10
2. ...

Ashwani Kumar
21/2/17
Assistant Engineer (QC) Lab.
DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC) Lab.
Quality Control Lab, Vikas Kutir, ITO
New Delhi