To

The Assistant Engineer(QC)
Quality Control Lab., DUSIB
Vikas Kutir, ITO, New Delhi

R.No. 0512

RECEIVED 30 MAY 2017

Part I

Dispatch No 3362/EEC-6/DUSIB/17-18---------- Date: 29/5/17

Sub: Testing of CC cubes of mix M-25 for 7/28 days Compressive Strength.

A. L. No. 85/WJ-69819(137)EEC-6/DUSIB/AE-II/16-17/D-1605 dt-03/03/17

1. Name of work: Pay & Use (JSC)

SH: Construction of 100 seater JSC at JJ Basti Sanjay Colony Y- Block at Plot No-Y-5 to Y-8 and back lane of Y-1 to Y-12 and ESS , Okhla Ind. Area Ph-II (Site-I) ID-8219

2.	Details from where sample is collected	From the Site of work----------
3.	Name of Circle/Division	Circle II/C-6 ----------
4.	Name of Junior Engineer	Sh Ramesh Kumar ----------
5.	Name of Assistant Engineer	Sh Amarnath----------
6.	Name of Executive Engineer	Sh. O.P. Pruthi ----------
7.	Name of Contractor/Agency	Sh. Prakash.----------
8.	Name of Officer collecting sample:	Sh Amarnath/ Sh. O.P. Pruthi ----------
9.	Date of collection:	----------
10.	Date of testing:	----------
11.	Required strength:	As per CPWD Specification, 250 Kg/sqm----------
12.	No. of specimen sent for testing:	--03----------
13.	Size of specimen:	15 X 15 X15 cm----------
14.	Mark of specimen:	----A----------

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample/ samples marked----A-----has/have been taken in my presence which represent 30 m3 approx quantity of works/supply made at site/store.

Signature of J.E
In charge of work

Signature of Contractor

Signature of Officer
taking sample (AE/EE)

Part II

TEST REPORT

No. SE(QC)/AE(Lab.)/2017-18 /D-

Date:

Test No. 0512 Date: 30.5.17

Date of Receipt: 30.5.17

Date of testing: 30.5.17

Concrete Mix: M-25

Days test: 28 days

S. No	Wt. of specimen in gms	Area in sq.cm.	Compressive Strength Load (Tonnes)	Compressive Strength Comp. strength (Kg./sq.cm)	Average Strength (Kg./sq.cm)	Remarks
1.	8162	225	63.00	280.00		
2.	8270	225	64.00	284.44	284.44	
3.	8244	225	65.00	288.89		

EE May Correlate Accordingly

Tested in my presence

Only testing has been conducted in this laboratory. The sample/samples has/have been collected and handed over by the field staff of the concerned division.

30/5/17

Assistant Engineer (QC-Lab)
DUSIB, Vikas Kutir ITO

Assistant Engineer (QC)
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-02

Copy to:-

1. EE/C-6
2. GC