

R. No 2650
RECEIVED 17 MAR 2017
Date: 16/3/17

Part I

No. D- 141 / A-2 III / C-7 / 2017

Sub: Testing of Bricks/Bricks tiles for Dimension/Compressive Strength.

1. Name of work: -SC/ST Basties Fund

Sub-Head — Construction of road by providing and laying RMC pavement in SC/ST Basti, for dhobi ghat sangam park AC-18 Model Town (Project ID-000008780)

Acceptance Letter No. : WI/6031/123/PG/EEC-7/2016-17/D-331 DATE-08/03/2017

- 2 Detail from where sample is collected: at site.
- 3 Name of Circle/Division: C-7
- 4 Name of Junior Engineer Sh. TARUN GAUR.....
- 5 Name of Assistant Engineer: Sh. R.D. Passi
- 6 Name of Executive Engineer: Sh. K. B.Sharma
- 7 Name of Contractor/Agency: M/s-Rakesh Kumar goel.
- 8 Name of Officer collection sample : Sh. R.D. Passi
- 9 Date of collection/Date of filling frog 14/3/17 13/3/17
- 10 Date of Testing: 17/3/17
- 11 Identification Mark: 121210
- 12 Class designation: 7.5
- 13 No. of specimen sent for testing: 05 Nos.

Specimen relating to work mentioned above is/are sent for testing. It is certified that the sample (S) marked has/have been taken in my presence which represent quantity of work/supply made at site/store.

Signature of JE
In-charge of work

Signature of Contractor

Signature of Officer
taking sample (EE/AE)

Part II

TEST REPORT

No. SE (QC)/AE (Lab)/2017/D- 4697

Date : 17/03/17

Test No. 2650 Date 17.3.17

Date of Receipt 17.3.17

Date of Testing 17.3.17

S. No.	Dimensions Length Width Area (cms) (cms) (sq.cm)	Maximum Strength Failure (T)	Compressive Strength failure (kg/sq.cm)	Average Compressive Strength kg/sq.cm
1.	22.00 x 10.60 = 233.20	21.00	90.05	95.03
2.	22.40 x 10.70 = 239.68	22.00	91.78	
3.	22.30 x 11.00 = 245.30	24.00	97.84	
4.	22.50 x 11.10 = 249.75	25.00	100.10/100.0	
5.	22.30 x 10.80 = 240.84	23.00	95.50	

DEMENSION TEST: FOR 20 BRICKS

1. Length :
2. Width : — NOT ASKED FOR —
3. Height :

Tested in my presence

Only testing has been conducted in this laboratory, the samples have been collected, cured, and handed over by the field staff of the concerned division.

Copy to:

1. E.C./C-7
2.

dlc

Assistant Engineer (QC) Lab.

DUSIB, Vikas Kutir, ITO

Assistant Engineer (QC)
DUSIB, Vikas Kutir, ITO
Delhi Urban Shelter Improvement Board
Govt. of N.C.T. of Delhi
ITO, New Delhi-110022